



## **Revel Environmental Manufacturing Inc.**

sales@remfilters.com (888) 526-4736 Lic. No. 857410

Northern California  
960-B Detroit Avenue  
Concord, California 94518  
P: (925) 676-4736  
F: (925) 676-8676

Southern California  
2110 South Grand Avenue  
Santa Ana, California 92705  
P: (714) 557-2676  
F: (714) 557-2679

## **Operation & Maintenance (O&M) and Procedures**

### **REM TRITON Filter Recommended Maintenance Procedures:**

#### **Maintenance and Inspections:**

In order to ensure proper operation, REM (Revel Environmental Manufacturing, Inc.) recommends that REM Stormwater filters be serviced and maintained when debris and pollutant accumulations exceed no more than 80% of the filter's capacity. REM recommends that the filters are inspected and serviced at a minimum of three times (3X's) per seasonal cycle year. The frequency and length of duration between inspections and maintenance may fluctuate based on specific site conditions such as local weather conditions, site use, and pollutant type and loading volume.

#### **Filter Media Replacement:**

In order to ensure proper operation, REM recommends that the FOG Media, or other specified media (such as Activated Carbon, and/or Zeolite) be replaced when the outer surface of media is no more than 50% coated with contaminants. (The surface area of REM's standard FOG media is stark white in color. The media will blacken with encapsulated contaminants over time.) It is recommended that REM media packs and Bioflex be replaced a minimum of one time (1X) per seasonal cycle year. Sites with higher pollutant loading concentrations may require more frequent service and media replacement. Purchase replacement media packs from REM at (888) 526-4736 or sales@remfilters.com. Custom media configurations are available upon.

#### **Disposal:**

Captured pollutant debris and spent media must be disposed of in accordance with all Federal, State, and Local Laws and Regulations.

#### **On-site Procedures for Triton Catch Basin Filter Inserts:**

1. Secure area (proceed with traffic and pedestrian control plan).
2. Clean surface area immediately around each storm drain utilizing a stiff bristled push-broom, flat shovel or industrial vacuum.
3. Proceed with confined space procedures as necessary.
4. Remove grate or manhole cover and set aside.
5. Inspect perimeter filter flange gasket. Confirm media cartridge is secure in the filter basin.
6. Remove debris trapped in grate slot openings.
7. Utilize an industrial vacuum to remove debris from within filter basin.
8. Pressure wash media pack through the stainless steel cartridge. (Avoid discharge by utilizing an industrial vacuum to remove excess water while pressure washing).
9. Inspect media housed inside stainless steel cartridge. REM recommends replacing the filter media a minimum of once a year (see *Filter Media Replacement* above).
10. Place grate or manhole cover back on catch basin grate frame.
11. Secure dated service lock-out tag on grate lid.
12. Identify catch basin on site map for tracking and reporting.
13. Note observations, concerns or recommendation regarding specific filter on maintenance report.
14. Remove pedestrian and/or traffic control barricades.